



Office & Laboratory : 32/41, South Side of G. T. Road, UPSIDC Industrial Area, Ghaziabad - 201 009, UP, INDIA.  
Contact No. : 9711159210, 9711159427, SMS/Whatsapp No. : 9711163422; E-mail : email@ekopro.in, ekoproengineers@gmail.com, website : www.ekopro.in

**TEST REPORT****Effluent Sample Analysis**

Test Report No. : EK0/EV-EW/101/291016

Issue Date : 03/11/2016

: NAINI PAPER LIMITED  
7th KM STONE  
MORADABAD ROAD  
KASHIPUR  
U.K.

Sample Description : Effluent After Treatment (ETP Outlet)  
Sample Drawn on : 28/10/2016  
Sample Drawn by : EPEPL(Mr. Sudesh Dubey)  
Sample Received on : 29/10/2016  
Sampling Location : NA  
Sampling Plan & Procedure : SOP-W/66  
Sample Quantity : 2.0 Litre  
Environmental Condition : Normal  
Analysis Duration : 29/10/2016 To 03/11/2016  
Remark (if any) : NA

**RESULTS**

S.No.	PARAMETER	Test Methods	Results	Units	LIMITS AS PER EPA*
1	pH	IS 3025(P-11)	7.46	-	5.5 - 9.0
2	Colour	Visual	Light Yellow	-	-
3	Total Dissolved Solids	IS : 3025 (P-16)	1280.0	mg/L	-
4	Total Suspended Solids	IS : 3025 (P-17)	25.0	mg/L	100.0
5	COD (as O <sub>2</sub> )	IS : 3025 (P-58)	102.5	mg/L	250.0
6	BOD (@27°C for 3 days)	IS : 3025 (P-44)	13.0	mg/L	30.0

\* Details as per EPA-1986 Schedule-VI Part-A, General Standards for Discharge of Effluents.

\*\*End of Report\*\*

**Notes :**

1. The results given above are related to the tested sample, as received & mentioned parameters. The customer asked for the above tests only.
2. This test report will not be generated again, either wholly or in part, without written permission of the Laboratory.
3. This test report will not be used for any publicity/legal purpose.
4. This test samples will be disposed off after two weeks from the date of issue of test report, unless until specified by the customer. Sample received for biological tests will be destroyed after 7 days from the date of issue of test report.
5. Responsibility of the Laboratory is limited to the invoiced amount only.

For EKO PRO ENGINEERS PVT. LTD  
GHAZIABAD  
Authorized Signatory